



THE CITY OF REDMOND
FIRE DEPARTMENT - PREVENTION DIVISION
**Redmond Fire Department Standards
Standard Revision Proposal**



Standard Section: 5.2.5.1.1.8 (added)

Standard Edition: Current

Date: September 20, 2000

Statement of Need:

The currently adopted NFPA 13 1994 edition does not require quick response sprinkler heads in light hazard occupancies. The use of quick-response sprinklers enhance property protection and life safety and are required in NFPA 13 1996 edition (5-2.1.3). The scope of this addition to our sprinkler standard deals with new system installations only and does not grant any design area reductions.

New Standard Language:

5.2.5.1.1.8: Sprinklers in light hazard occupancies shall be of the quick-response type as defined in NFPA 13 1994 edition 1-4.5.1.

Exception No. 1: Residential sprinklers are permitted in accordance with NFPA 13 1994 edition 4-3.6.

Robert Lovett
Fire Marshal