IFC REQUIRED INSTALLATION PERMITS

105.6.5 Battery Systems

To install stationary lead-acid battery systems having a liquid capacity of more than 50 gallons.

105.6.22 HPM Facilities

Install specialized equipment or create a new HPM facility

105.6.23 High-Piled Storage

To use a building or portion thereof as a high-piled storage area exceeding 500 sq. ft.

105.6.39 Refrigerant Equipment

To install refrigerant equipment, refrigerant machinery rooms, treatment/flaring /ammonia diffusion systems.

105.7.2 Compressed gases.

When the compressed gases in use or storage exceed the amounts listed in Table 105.6.9, a construction permit is required to install, repair damage to, abandon, remove, place temporarily out of service, or close or substantially modify a compressed gas system.

105.7.5 Flammable and combustible liquids.

- 1. To repair or modify a pipeline for the transportation of flammable or combustible liquids.
- 2. To install, construct or alter tank vehicles, equipment, tanks, plants, terminals, wells, fuel-dispensing stations, refineries, distilleries and similar facilities where flammable and combustible liquids are produced, processed, transported, stored, dispensed or used.
- 3. To install, alter, remove, abandon or otherwise dispose of a flammable or combustible liquid tank.

105.7.6 Hazardous materials.

To install, repair damage to, abandon, remove, place temporarily out of service, or close or substantially modify a storage facility or other area regulated by Chapter 27 when the hazardous materials in use or storage exceed the amounts listed in Table 105.6.21.

105.7.7 Industrial ovens.

For the installation of industrial ovens covered by Chapter 21.

105.7.8 LP-gas.

For the installation of or modification to an LP-gas system.

105.7.9 Private fire hydrants.

For the installation or modification of private fire hydrants.

105.7.10 Spraying or dipping.

To install or modify a spray room, dip tank or booth.